

**To:** OPW Fueling Containment Systems Certified Contractors, Distributors, Reps,  
Customer Service

**From:** Fran Koh

**Date:** October 25, 2005

**Subject:** GeoDuct Cross Over

OPW Fueling Containment Systems requires a minimum separation of two inches (2") of compacted approved pea gravel or crushed stone or four inches (4") of approved compacted sand backfill material when crossing over two sections of GeoDuct conduit chase piping. All backfill materials should be clean and free of sharp objects and debris. All other applicable trenching and backfill requirements must be also be followed.

If you have any questions, please feel free to contact our Customer Service Department at 866-547-1816 or our Technical Services Department at 919-934-2786 x110.