



SiteSentinel
Integra 100™



SiteSentinel
Integra 500™



Environmental Compliance Matrix

In-Tank Leak Test	SiteSentinel Integra Console	925B Mag Probe	SLD	MagLLD	CVMS Vacuum Monitoring	Mag Sump Sensor	Discriminating Containment Sensor	Discriminating Interstitial Sensor	Non-Discriminating Containment Sensor	Non-Discriminating Interstitial Sensor	Dry Well Sensor	Wet Well Sensor
Monthly Monitoring-Tanks												
0.2 GPH Automatic In-Tank Leak Test	✓	✓										
0.2 GPH Automatic In-Tank Leak Test	✓											
0.2 GPH Continuous Statistical Leak Detection Test	✓	✓	✓									
Manifold Tank Leak Detection Capability	✓	✓	✓									
Large Tank Leak Detection Capability > 20,000 gal.	✓	✓	✓									
Automatic Test (ALD Feature)	✓	✓										
Monitoring Interstitial Area of Tank	✓											
Continuous Vacuum Monitoring for Tank Interstice	✓				✓							
Dry Well Monitoring for Tank Field	✓										✓	
Wet Well Monitoring for Tank Field	✓										✓	✓
Annual Monitoring-Tanks												
0.1 GPH Precision Automatic Tank Tightness Testing	✓											
Catastrophic Monitoring/Testing												
3.0 GPH Catastrophic Line Leak Test	✓			✓								
Continuous Vacuum Monitoring for product lines	✓				✓							
Monthly Monitoring-Piping												
0.2 GPH Automatic Monthly Leak Test	✓			✓								
Monitoring Interstitial Area of Piping	✓							✓		✓		
Monitoring Containment Area, Sumps/Pans	✓					✓	✓		✓			
Continuous Vacuum Monitoring for product lines	✓											
Dry Well Monitoring for Piping Field	✓										✓	
Wet Well Monitoring for Piping Field	✓											✓
Annual Monitoring-Piping												
0.1 GPH Monthly Leak Test	✓			✓								

Leading The Way in Electronic Fuel Management Systems

Phone: (708) 485-4200 ♦ Fax: (708) 485-4630 ♦ 6900 Santa Fe Drive ♦ Hodgkins, Illinois USA 60525

www.opwglobal.com

* All competitive data gathered from national work group leak detection evaluations, and subject to change.



Federal Regulations

COMPONENTS	REQUIREMENTS
New Tanks	<ul style="list-style-type: none"> · Monthly Monitoring · Inventory Control
Existing Tanks	<ul style="list-style-type: none"> · Monthly Monitoring · Inventory Control
New and Existing Pressurized Piping	<ul style="list-style-type: none"> · Monthly Monitoring · Automatic Shutoff Device · Flow Restrictor · Continuous Alarm System · Annual Line Tightness Test
New and Existing Suction Piping	<ul style="list-style-type: none"> · Monthly Monitoring · Line Tightness Test
SPILL AND OVERFILL PREVENTION	
All Tanks	<ul style="list-style-type: none"> · Catch Basin · Automatic Shutoff Devices · Overfill Alarms · Ball Float Valves
CORROSION PROTECTION	
New Tanks and Piping	<ul style="list-style-type: none"> · Coated and Cathodically Protected Steel · Fiberglass Reinforced Plastic FRP · Steel Tank Clad With FRP
Existing Tanks and Piping	<ul style="list-style-type: none"> · Cathodically Protected Steel · Tank Interior Lining · Tank Interior Lining and Cathodic Protection