

OPW[®] INSTRUCTIONS

OPW 5-B AND 5-BP SPOUT ASSEMBLY REPLACEMENT INSTRUCTIONS


The 5-B Spout Assembly is the replacement spout assembly for OPW 11-A Series Automatic Nozzles, for use with leaded gasoline. The 5-BP small diameter (13/16") spout assembly is the replacement spout assembly for OPW 11-AP Series Automatic Nozzles, for use with unleaded gasoline.

**CAUTION: FOLLOW THESE STEPS EXACTLY
FOR EASY SPOUT REPLACEMENT**

NOTE: DO NOT USE WITH 11-B SERIES NOZZLE

1. Remove plastic fender guard. Save for reuse later.
2. Remove spout retaining screw from the underside of nozzle near spout end, and pull the old spout assembly out of the nozzle. Also remove the old seal rings. Throw the old parts away. Be sure there is no dirt or foreign matter in the outlet end of nozzle.
3. Remove tape from the new spout assembly, and coat both seal rings with a heavy lubricating oil. Remove the spout retaining screw.
4. Place both seal rings on the spout assembly as shown in Fig. 1.
5. Insert the new spout assembly gently, but firmly, into the outlet end of the nozzle with a slight twisting motion until it will go no farther. Rotate the spout until the retaining screw hole in the adaptor is in line with the screw hole in the nozzle.
6. Insert spout retaining screw and tighten firmly. Replace plastic fender guard.
7. Test nozzle for shut-off in all clip positions. Remove nozzle from service if it fails to shut-off.

**FIG. 1
NEW SPOUT ASSEMBLY**




IT IS IMPORTANT THAT THE O-RINGS ARE LUBRICATED AND THAT THE SPOUT IS INSERTED WITH A GENTLE BUT FIRM SLIGHT TWISTING MOTION. FAILURE TO FOLLOW THESE INSTRUCTIONS MAY DAMAGE THE O-RINGS AND RESULT IN NOZZLE FAILURE.

OPW[®]

FUELING COMPONENTS
A COVER RESOURCES COMPANY
P. O. Box 405003 • Cincinnati, Ohio 45240-5003
(513)870-3219 • (800)422-2525 (Orders Only)
(513)870-3100 (Other Calls)



ONE COMPANY. ONE WORLD. ONE SOURCE.



OPW TERMS & POLICIES

Notice: OPW/PISCES by OPW Inc. products must be used in compliance with applicable federal, state, provincial, and local laws and regulations. Product selection should be based on physical specifications and limitations and compatibility with the environment and material to be handled. OPW/PISCES by OPW Inc. makes no warranty of fitness for a particular use. All illustrations and specifications in this literature are based on the latest production information available at the time of publication. Prices, materials, and specifications are subject to change at any time, and models may be discontinued at any time, in either case, without notice or obligation.

OPW STANDARD PRODUCT WARRANTY

OPW/PISCES by OPW Inc. warrants that products sold by it are free from defects in materials and workmanship for a period of one year from the date of manufacture by OPW/PISCES by OPW Inc. (ECO systems two years from date of manufacture. ECO replacement parts one year from the date of manufacture.) Proof of purchase may be required. For any product certified to California 2001 standards*, OPW/PISCES by OPW Inc. warrants that products sold by it are free from defects in material and workmanship for a period of one year from date of manufacture or one year from date of registration of installation not to exceed 15 months from date of manufacture by OPW/PISCES by OPW Inc. As the exclusive remedy under this limited warranty, OPW/PISCES by OPW Inc. will at its sole discretion, repair, replace, or issue credit for future orders for any product that may prove defective within the one year date of manufacture period (repairs, replacements, or credits may be subject to prorated warranty for remainder of the original warranty period, complete proper warranty claim documentation required.)

PISCES by OPW, Inc. further guarantees that all PISCES primary pipe is free from defects in materials and workmanship for a period of ten (10) years from the date of manufacture. Any PISCES primary pipe proven to be Defective in materials or workmanship within said 10-year period will, at PISCES option, be repaired or replaced, or credit will be given for future orders. PISCES will bear the reasonable labor costs associated with the repair or replacement of non-conforming PISCES primary pipe when such pipe has been used exclusively in a complete PISCES Retractable System. Any defect will be corrected promptly upon written notification to PISCES by OPW, Inc. at P.O. Box 405003 Cincinnati, Ohio 45240, attention Rick Jones.

This warranty shall not apply to any product that has been altered in any way, which has been repaired by any other than a service representative authorized by OPW/PISCES by OPW Inc. or when failure is due to misuse, improper installation or maintenance. OPW/PISCES by OPW Inc. shall have no liability whatsoever for special, incidental, or consequential damages to any party, and shall have no liability for the cost of labor, freight, excavation, clean-up, downtime, removal, reinstallation, loss of profit, or any other cost or charges.

**Products certified to the California 2001 standards will have an OPW registration card enclosed/attached to the product.*

THIS WARRANTY IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESSED OR IMPLIED, AND SPECIFICALLY THE WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. THERE ARE NO WARRANTIES WHICH EXTEND BEYOND THE DESCRIPTION ON THE FACE HEREOF.

CUSTOMER SERVICE DEPARTMENT

North America Toll Free - TELEPHONE: (800) 422-2525 or FAX (800) 421-3297

Email: domesticsales@opw-fc.com

www.opw-fc.com