

To: OPW Fueling Containment Systems Certified Contractors, Reps, Customer Service

From: Fran Koh – Technical Services

Date: June 16, 2005

Subject: 2” Double Entry Boots: DEB-6200

When using the DEB-6200 double entry boots with GeoFlex piping, you must insert the pipe through the entry boot prior to coupling the pipe. The nut of the SPC-0200 will not fit through the outer portion of the boot. A remote coupling machine may also be used in this application if the boots were previously installed.