

Technical Memo

Number 2006-1

То:	OPW Fueling Containment Systems Certified Contractors, Distributors, Reps, Customer Service
From:	Patrick Schultz
Date:	April 20, 2006
Subject:	GeoFlex+Plus Swages

Since GeoFlex+Plus pipe is slightly more rigid than our GeoFlex pipe, OPW FCS recommends that new swages be used to replace old swages when installing our new GeoFlex+Plus pipe.

Our product numbers for our Swage Kits are as follows:

CSK-0075S	Coupling Swage Kit	3/4"	Box	Used to attach 3/4" Swivel Couplings to flex pipe
CSK-0100S	Coupling Swage Kit	1″	Box	Used to attach 1" Swivel Couplings to flex pipe
CSK-0150S	Coupling Swage Kit	1-1/2″	Box	Used to attach 1-1/2" Swivel Couplings to flex pipe
CSK-0150C	Coupling Swage Kit-Coax		Box	Used to attach 1-1/2" Coax Couplings to flex pipe
CSK-0200S	Coupling Swage Kit		Box	Used to attach 2" Swivel Couplings to flex pipe
CSK-0200C	Coupling Swage Kit-Coax	2"	Box	Used to attach 2" Coax Couplings to flex pipe
CSK-0300S	Coupling Swage Kit	3"	Box	Used to attach 3" Swivel Couplings to flex pipe

Please feel free to contact our Customer Service Department at 866-547-1816, or our Technical Service Department at 919-934-2786 x110 if you have any questions or concerns.